

# CE TEST CERTIFICATE


FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-19-01-25-01


- Products:** Laminate floor coverings of the collection „EGGER LAMINATE DPL 6-12 mm“
- Client:** EGGER Holzwerkstoffe Wismar GmbH & Co. KG  
Am Haffeld 1  
23970 Wismar
- Order:** Determination of the electrostatic behaviour according to EN 1815:2016 /  
Classification according to EN 14041:2008
- Test reports:** 2718654
- Test results:** The above mentioned collection of laminate floor coverings can be classified regarding to the property “Electrostatic behavior“ according to EN 14041:2008 (CE-labelling) as follows:

Property	Determined values	Declaration according to EN 14041:2008
Body voltage in walking test according EN 1815:2016	0.0 – 0.3 kV	Antistatic floor covering

Dresden, 25/01/2019

  
Head of laboratory



  
Engineer in charge